


Dr. Eng. Adriano Marin
WOW TECHNOLOGY S.p.A.

Outperforming liquid RW treatment designed for application in nuclear field and in decommissioning

Fluid Dynamics Technology

WOW proprietary technology performs a **localized molecular separation** between solute and suspended elements and the solvent.




Standard process vs WOW process

The selective evaporation improves the abatement factor or decontamination factor by thousands of times in respect to any standard evaporator.

Continuous Process

Thanks to the **full control of the drag/entrainment effect**, no batches are required to reach the desired Decontamination Factor.



No Secondary Waste

No filters, membranes, resins or additives are used to carry on the process. Moreover, **the equipment self decontaminates** after use.

Automated and Transportable

Fault Tolerant & Failure Proof - Automated and remote controlled, the equipment is **modular for transportability** and **tailored** to the application.

Tested and Certified

1 Test with first device, at Applied Nuclear Energy Laboratory (LENA) of the University of Pavia

Continuous Operation:	20 litres/day for 39 days
Contaminants Concentration:	1,500 mg/l of ¹³³ Cs totally soluted + 2 radioactive tracers: ¹³⁴ Cs (4.2MBq) few µg, ¹³⁷ Cs (3.6MBq) few µg
Conc. Level Simulation:	4.8 TBq/l typical of HLW 6,000 times higher than Fukushima-Daiichi cooling water

Certified Results

Min. Decontamination Factor (DF) DF > 7,500

Removal Efficiency 99.986%

2 Real case application of the improved device, on LLW: treatment of 1,000lt. of decontamination solution produced by the Radiochemistry Laboratory of the University of Pavia.

Certified Results

RADIOISOTOPES	MEASURED DECONT. FACTORS (DF)
¹³⁷ Cs	40,338
¹³⁴ Cs	39,744
²⁴¹ Am	33,425
¹⁰⁹ Cd	18,735
⁶⁰ Co	7,581

Final residual concentrated waste solution < 1 Lt

3 Full scale industrial application: Nuclear repository of Saluggia (IT)



Certified: by British National Physics Lab. - NPL by site operator and University of Pavia - LENA

(*) output activity much lower than MDA | (**) Uncertainty 3% | (***) Measures conducted on several samples: output activity is extremely low and concentrated solution of the boiler has some sediments | (Δ) NPL didn't issue here any test report (ND) | (ΔΔ) Test at NPL labs is still on going.

Continuous Operation:	Average ≈410litres/day for 120 days → total ≈50,000 Lt
Initial liquid characteristics	pH = 4.6; Fluorides <1mg/l; Chlorides ≈15mg/l; Nitrates <5mg/l; Sulfates ≈303mg/l; Phosphates Absent; Sodium ≈22mg/l; Potassium ≈11mg/l; Magnesium ≈6mg/l; Calcium ≈94mg/l.
Radioisotopes	LLW of ¹³⁷ Cs ; ⁶⁰ Co ; ²⁴¹ Am ; ⁹⁰ Sr

Certified Results

Radio-nuclides	Measures by	Decontamination Factor (DF)			
		After 30 Days	After 60 Days	After 90 Days	After 120 Days
¹³⁷ Cs	UNIPV-LENA and by N.P.L.	80,000 (**)(Δ)	142,000 ÷ 168,000 (**)	107,000 ÷ 412,000 (***)	335,000 (**)(ΔΔ)
⁶⁰ Co	UNIPV-LENA and by N.P.L.	56,000 (Δ)	161,000 ÷ 178,000	520,000 ÷ 685,000	>890,000 (*) (ΔΔ)
²⁴¹ Am	UNIPV-LENA and by N.P.L.	>23,000 (Δ)	>5,290 (*) + >238,400 (*)	>300,000 (*)	>> (*) (ΔΔ)
⁹⁰ Sr	UNIPV-LENA and by N.P.L.	>2,044 (*) (Δ)	>26,200	>66,760 (*) + >96,000 (*)	>91,470 (*) (ΔΔ)


Fukushima-Daiichi case study



Reference data are public parameters of Fukushima-Daiichi:

Water volume to be purified every 120days:	100,000 m ³
Inlet contamination level:	830 MBq/l
Contaminant agent:	¹³⁷ Cs (26kg in total)
Allowable activity in water after treatment:	300 Bq/l
Required Decontamination Factor (DF):	2.77 x 10 ⁶

With reference to full scale certified WoW's Decontamination Factor (DF) ≈330,000 the following feedback cascade configuration & control of concentration has been designed



Considering the following treatment flux:
1° WOW device - 980m³/day (max stage concentration = 250)
2° WOW device - 840m³/day (max stage concentration = 130)
3° WOW dryer - 45m³/day (max stage concentration ≈ 63)

Considering current decontamination solutions the **total DF parameter obtained with this WOW configuration is at least 10,000-13,000 times**, according to public data reports, **greater** than with the currently used systems.

Expected performance for every 120 days operation cycle:

Total volume of contaminated water fed to WOW	100,000 m³
Purified water output (max 300Bq/l)	99,979 m³
Final volume of concentrated waste (*)	8 m³
Final total waste volume ratio	12,500

Note (*): where practically all the contamination is concentrated and removed from initial solution. 8m³ is the minimum volume that can be reached as in this case the concentration of ¹³⁷Cs radioisotope is 3.23gr/l and so its decay is producing a self-heating up to 26 °C.